

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region I - EPA New England

Drafted Date: October 16, 2014
Finalized Date: October 17, 2014

SUBJECT: Partial Compliance Evaluation of Inland Fuels Terminal, East Hartford, CT

FROM: Elizabeth Kudarauskas, Environmental Engineer, Air Technical Unit *EAR*

THRU: Christine Sansevero, Senior Enforcement Coordinator, Air Technical Unit *CMS 10/23/14*

TO: File

I. Facility Information

- A. Facility Name: Inland Fuels Terminal
- B. Facility Location: 530 Main Street, East Hartford, CT
- C. Facility Mailing Address: same
- D. Facility Contact: Mark Rooslund
- E. Type of Source (major/minor/sm/sm80): minor
- F. Date Title V permit issued: NA
- G. AFS #:

II Background Information

- A. Date of inspection: September 17, 2014
- B. Weather Conditions: partly cloudy, temperatures in the 70's
- C. US EPA Representative(s):
 - Beth Kudarauskas, Air Tech Unit, OES
 - Mike Looney, OEME
 - Jerome Keefe, OEME
- D. State Representative(s):
 - none
- E. Federal Requirements Discussed
 - 40 CFR Part 63 Subpart R
 - 40 CFR Part 63 Subpart BBBBBB
 - 40 CFR Part 60 Subpart XX

III Purpose of Inspection

The purpose of this inspection was to conduct monitoring to determine whether excess VOC emissions were being emitted from the facility.

EPA also used the inspection to gather information on the storage and distribution of #6 oil and asphalt at the terminal.

IV Facility Description

A. Company / Facility History

The Inland Fuels Terminal in East Hartford, CT is a petroleum storage and distribution terminal. Products stored on-site include diesel and home heating oil. No gasoline or ethanol is stored or distributed at this facility.

B. Corporate Structure and CEO/President/owner name and mailing address

According to the Inland Fuels website, the company owns several petroleum storage and distribution terminals in New England. Also from the company website, the East Hartford, CT terminal was purchased by Inland Fuels in October 2013.

V Inspection

A. Entry

The inspectors arrived unannounced at the Inland Fuel Terminal facility located on Main Street in East Hartford at approximately 12:00 pm. The EPA inspectors (Ms. Kudarauskas, Mr. Looney and Mr. Keefe) showed their credentials to Mr. Mark Rooslund.

B. Opening Conference

Ms. Kudarauskas explained that the purpose of the inspection was to determine Inland Fuel's compliance with Clean Air Act Regulations. Mr. Rooslund explained that he was the only person on-site at the time. Mr. Rooslund explained that Wayne Schnell is the Terminal Supervisor.

Ms. Kudarauskas asked Mr. Rooslund if the facility handled any gasoline, ethanol or other chemicals. Mr. Rooslund stated that the facility did not handle any gasoline, ethanol, or chemicals. In addition, Mr. Rooslund stated that the Inland Fuels terminal does not handle any heavy oil products such as #6 oil or asphalt. Mr. Rooslund stated that the terminal only handles #2 heating oil and diesel for trucks.

Inland Fuels does not operate a fleet of trucks.

C. Plant Walkthrough

No formal facility walkthrough was conducted, however, the inspectors did briefly walk around the facility before leaving.

Ms. Kudarauskas observed that the loading rack consisted of 3 top loading bays. This type of

loading rack is indicative of a facility that does not have the capacity to load gasoline. In addition, gasoline tanker trucks typically bottom load product, which requires a different loading rack configuration from the configuration at Inland Fuels. Furthermore, the inspectors did not detect any gasoline odors at the facility. Ms. Kudarauskas observed only petroleum storage tanks that would be typical for the storage of #2 oil or diesel. Ms. Kudarauskas did not observe any tanks that would indicate gasoline storage, or heated and insulated heavy oil storage.

Based on this, it does not appear that gasoline is distributed at the facility.

D. Closing Conference

Mr. Rooslund provided the following contact information for follow-up questions:

Wayne Schnell, Terminal Supervisor
Cell: 860-942-2593

Ed, Owner
Cell: 860-883-5107

Inland Fuels Terminal East Hartford terminal phone number: 860-342-2214.

The inspectors thanked Mr. Rooslund for his time and left the facility at approximately 12:15 pm.

